

# SOURCE WATER ASSESSMENT REPORT

## AN EVALUATION OF THE SUSCEPTIBILITY OF PUBLIC DRINKING WATER SOURCES TO POTENTIAL CONTAMINATION

APA 100

### New Britain Water Department White's Bridge Upper Wellfield

The State of Connecticut Department of Public Health (DPH) in cooperation with the Department of Environmental Protection (DEP) recently completed an assessment of the White's Bridge Upper Wellfield, which is a source of public drinking water that is maintained and operated by the New Britain Water Department. This one-time assessment is part of a nationwide effort mandated by Congress under the Safe Drinking Water Act Amendments of 1996 to evaluate the susceptibility of all public drinking water sources in Connecticut to potential sources of contamination. DPH began working in partnership with the DEP in 1997 to develop Connecticut's Source Water Assessment Program, which was approved by the U.S. Environmental Protection Agency in 1999. Sources of potential contamination that are of concern to public drinking water supplies here in Connecticut are generally associated with historic waste disposal or commercial, industrial, agricultural and residential properties that store or use hazardous materials like petroleum products, solvents or agricultural chemicals.

The assessment is intended to provide New Britain Water Department consumers with information about where their public drinking water comes from, sources of potential contamination that could impact it, and what can be done to help protect it. This assessment will also assist the public water supply system, regional planners, local government, public health officials and state agencies in evaluating the degree to which the White's Bridge Upper Wellfield may be at risk from potential sources of contamination. The assessment can be used to target and implement enhanced source water protection measures such as routine inspections, protective land use regulations, acquisition of critical land, proper septic system maintenance, and public education. General sources of contamination with the potential to impact the White's Bridge Upper Wellfield include properties with underground fuel storage tanks, improperly maintained on-site septic systems, improper waste disposal, or commercial/industrial sites that store or use chemicals or generate hazardous wastes.

#### White's Bridge Upper Wellfield Source Water Assessment Summary

##### STRENGTHS

**Public Water System Source Protection Program**

**Less than 10% of this source water area is currently developed for commercial or industrial use**

##### POTENTIAL RISK FACTORS

**Potential contaminant sources in source water area**

**No local aquifer protection regulations**

##### Susceptibility Rating

Rating	Environmental Sensitivity	Potential Risk Factors	Source Protection Needs
Low	X		
Moderate		X	
High			X

**Overall Susceptibility Rating: High**

*This rating indicates susceptibility to potential sources of contamination that may be in the wellfield source water area and does not necessarily imply poor water quality.*

Detailed information about the specific factors and information used in establishing this rating can be found in Table 1. Information about opportunities to improve protection in the White's Bridge Upper Wellfield source water area is also presented in Table 2.



Keeping Connecticut Healthy

State of Connecticut Department of Public Health

**Drinking Water Division**

410 Capitol Avenue – MS# 51WAT  
P.O. Box 340308 Hartford, CT 06134  
(860) 509-7333

**OVERVIEW** - The White's Bridge Upper Wellfield is located in an aquifer that is comprised largely of water-bearing sand and gravel deposits. The source water area is delineated by a preliminary Level B aquifer protection mapping area, which encompasses some 1900.6 acres of land in Bristol and Burlington. Vacant land and residential properties in the White's Bridge Upper Wellfield source water area presently account for approximately 93.8 percent of the land cover. Commercial development at 0.5 percent and agricultural land use at 5.7 percent, account for the remainder of the land coverage's in the source water area. Information about drinking water quality and treatment is available in the New Britain Water Department's annual Consumer Confidence Report.

**ASSESSMENT METHODS.**

The drinking water source assessment methods used by the Department of Public Health Drinking Water Division to evaluate the susceptibility of public drinking water sources to contamination are based on criteria individually tailored to surface water and groundwater sources. The criteria are keyed to sanitary conditions in the source water area, the presence of potential or historic sources of contamination, existing land use coverage's, and the need for additional source protection measures within the source water area. Source-specific data for community and non-community systems were used to determine whether a particular criterion should be rated as low, moderate or high, relative to the risk of potential contamination at the drinking water source. Further, a ranking system was used to compute an average rank for each community drinking water source based on its environmental sensitivity, potential risk of contamination and source protection needs.

Wellfields rated as having a low, moderate or high susceptibility to potential sources of contamination generally exhibit the characteristics summarized in Table 1.

**Table 1 – General Source Water Area Characteristics and Susceptibility Ratings**

<b>Susceptibility Rating</b>	<b>General Characteristics of the Source Water Area*</b>
Low	Low density of potential contaminant sources Lower intensity of land development
Moderate	Low to moderate density of potential contaminant sources Moderate intensity of land development
High	Moderate to high density of potential contaminant sources Higher intensity of land development No local aquifer protection regulations Detectable nitrates and/or volatile organic chemicals in the untreated source water during the past three years that are below the maximum contaminant levels allowed by state and federal drinking water regulations

*\* Note: Not all characteristics may be present for a given susceptibility rating*

*Readers of this assessment are encouraged to use the attached glossary to assist in the understanding of the terms and concepts used throughout this report.*

*Maps representing the location and features of the White's Bridge Upper Wellfield source water area have not been included with this assessment report because of homeland security concerns*

**WHITE'S BRIDGE UPPER WELLFIELD ASSESSMENT RESULTS.**

Based on a combination of current wellfield and source water area conditions, existing potential contaminant sources, and the level of source protection measures currently in place, the source water assessment for this wellfield indicates that it has an overall High risk of contamination from identified potential sources of contamination. It should be noted that this rating does not necessarily imply poor water quality or ongoing violations of the Connecticut Public Health Code. The assessment findings for the White's Bridge Upper Wellfield are summarized in Table 2, which lists current conditions in the wellfield source water area and recommendations or opportunities to enhance protection of this public drinking water source. A listing of potential contaminant source types in the area can be found in Table 3. A summary of source water area features is shown in Table 4.

The assessment of this and other comparable wellfields throughout Connecticut generally finds that adopting recommendations similar to those presented in Table 2 could reduce the susceptibility of most groundwater sources to potential sources of contamination.

Table 2

**Source Water Assessment Findings and Source Protection Opportunities  
White's Bridge Upper Wellfield**

<b>Assessment Category</b>	<b>Conditions Through June 2002</b>	<b>Recommendations and Source Protection Opportunities</b>
<p><b>Environmental Sensitivity Factors</b></p> <p><b>Contaminants Detected in Untreated Source Water</b></p>	<p>All wells in the White's Bridge Upper Wellfield are sited and constructed in accordance with DPH regulations and the most recent DPH sanitary survey of this wellfield indicates that it is free of deficiencies.</p> <p>None</p> <p>Except where noted above, any detected contaminants listed are below maximum contaminant levels (MCL) established by the federal government or guidance levels established by the Connecticut Department of Public Health. The presence of these contaminants, in general, indicates that this wellfield is sensitive to human activity.</p> <p><a href="#">Click here to review EPA's current drinking water standards</a>T</p>	<p>Maintain monitoring levels specified in the Connecticut Public Health Code Section 19-13-B102</p> <p>Encourage homeowners to adopt residential best management practices that minimize the use hazardous materials or generation of hazardous waste.</p>
<p><b>Potential Risk Factors</b></p>	<p>Potential contaminant sources in source water area</p> <p>More than 30% of land for this source water area is undeveloped, which could present a risk if developed inappropriately.</p>	<p>Periodically inspect SPCS sites and maintain a water quality monitoring program consistent with the level of potential risk</p> <p>Proactively work with local officials and developers to insure that only low-risk development occurs within the source water area</p> <p>Encourage residential property owners to conduct scheduled inspections and maintenance of underground fuel storage tanks and on-site septic systems.</p>
<p><b>Source Protection Needs Factors</b></p>	<p>Level B aquifer mapping completed</p> <p>Portions of the 200 foot sanitary radius around wellheads for this wellfield are not owned or controlled by the public water system.</p> <p>Local aquifer protection regulations have not been adopted for this source water area</p> <p>Less than 10% of the land in the source water area exists as preserved open space</p>	<p>Complete Level A mapping</p> <p>Where feasible, increase ownership or control of 200 foot sanitary radius around all wellheads for this wellfield</p> <p>Develop and adopt local aquifer protection regulations</p> <p>Support and encourage the acquisition of open space land within the source water area</p> <p>Support environmental awareness and education within the community.</p>

Inventoried significant potential contaminant sources in the White's Bridge Upper Wellfield source water area are listed in Table 3. While these facilities have the potential to cause groundwater contamination, there is no indication that they are doing so at this time.

**Table 3 Summary of Significant Potential Contaminant Types in the White's Bridge Upper Wellfield Source Water Area**

Category	Subcategory	Number of SPCS Types
Waste Storage, Handling, Disposal	Hazardous Waste Facilities	0
	Solid Waste Facilities	0
	Miscellaneous	0
Bulk Chemical, Petroleum Storage	Underground Storage Tanks	11
	Tank Farms	0
	Warehouses	0
Industrial Manufacturing / Processing	Chemical & Allied Production	0
	Chemical Use Processing	1
	Miscellaneous	2
Commercial Trades and Services	Automotive and Related Services	3
	Chemical Use Services	3
	Miscellaneous	1
Agriculture and Related	Pesticide Storage, Handling or Application	0
Total Number of Contaminant Types		21

Prominent features of the White's Bridge Upper Wellfield source water area are summarized in Table 4.

**Table 4 Features of the White's Bridge Upper Wellfield Source Water Area**

Number and Type of Public Drinking Water Supply Wells	6 stratified drift wells
Source Water Area Delineation Method <sup>a</sup>	preliminary Level B
DEP Groundwater Classification	GAA - Groundwater used as a public drinking water supply, presumed to be drinkable without treatment
Size of Source Water Area	1900.6 acres
Location of Source Water Area	Bristol and Burlington
Predominant Land Use and Land Cover in Source Water Area <sup>b</sup>	
-Urban - Commercial or Industrial	0.5 %
-Urban - Residential	54.2 %
-Agricultural	5.7 %
-Undeveloped Land	39.6 %
Preserved Land In Source Water Area <sup>d</sup>	32.2 acres
Significant Potential Contamination Sources	
-Number of inventoried facilities in source water area	31
-Count of inventoried facilities per square mile	10.44 per sq mile
-Number of contaminant sources within inventoried facilities	21
Number of Contaminant Release Points Inventoried by CTDEP <sup>c</sup>	0

<sup>a</sup> Source water delineation method depends on data available for the wellfield

<sup>b</sup> Based on statewide data layer of land use and land cover developed by UCONN Dept of Natural Resource Management Engineering and Connecticut DEP satellite imagery.

<sup>c</sup> Sites or locations with documented accidental spills, leaks or discharges. While these sources, which are cataloged and tracked by the Connecticut DEP, may fall within a public drinking water supply source water area, they may or may not presently be discharging to the environment or causing contamination of a public drinking water source.

<sup>d</sup> Any combination of state forest and parklands and municipally or privately held land designated as open space.

# SOURCE WATER ASSESSMENT REPORT

## AN EVALUATION OF THE SUSCEPTIBILITY OF PUBLIC DRINKING WATER SOURCES TO POTENTIAL CONTAMINATION

APA 155

### New Britain Water Department White's Bridge Lower Wellfield

The State of Connecticut Department of Public Health (DPH) in cooperation with the Department of Environmental Protection (DEP) recently completed an assessment of the White's Bridge Lower Wellfield, which is a source of public drinking water that is maintained and operated by the New Britain Water Department. This one-time assessment is part of a nationwide effort mandated by Congress under the Safe Drinking Water Act Amendments of 1996 to evaluate the susceptibility of all public drinking water sources in Connecticut to potential sources of contamination. DPH began working in partnership with the DEP in 1997 to develop Connecticut's Source Water Assessment Program, which was approved by the U.S. Environmental Protection Agency in 1999. Sources of potential contamination that are of concern to public drinking water supplies here in Connecticut are generally associated with historic waste disposal or commercial, industrial, agricultural and residential properties that store or use hazardous materials like petroleum products, solvents or agricultural chemicals.

The assessment is intended to provide New Britain Water Department consumers with information about where their public drinking water comes from, sources of potential contamination that could impact it, and what can be done to help protect it. This assessment will also assist the public water supply system, regional planners, local government, public health officials and state agencies in evaluating the degree to which the White's Bridge Lower Wellfield may be at risk from potential sources of contamination. The assessment can be used to target and implement enhanced source water protection measures such as routine inspections, protective land use regulations, acquisition of critical land, proper septic system maintenance, and public education. General sources of contamination with the potential to impact the White's Bridge Lower Wellfield include properties with underground fuel storage tanks, improperly maintained on-site septic systems, improper waste disposal, or commercial/industrial sites that store or use chemicals or generate hazardous wastes.

#### White's Bridge Lower Wellfield Source Water Assessment Summary

##### STRENGTHS

##### **Public Water System Source Protection Program**

**Less than 10% of this source water area is currently developed for commercial or industrial use**

##### POTENTIAL RISK FACTORS

##### **Potential contaminant sources in source water area**

**No local aquifer protection regulations in more than 50% of source water area**

##### Susceptibility Rating

	Environmental Sensitivity	Potential Risk Factors	Source Protection Needs
Rating			
Low	X		
Moderate		X	
High			X

##### **Overall Susceptibility Rating: High**

*This rating indicates susceptibility to potential sources of contamination that may be in the wellfield source water area and does not necessarily imply poor water quality.*

Detailed information about the specific factors and information used in establishing this rating can be found in Table 1. Information about opportunities to improve protection in the White's Bridge Lower Wellfield source water area is also presented in Table 2.



Keeping Connecticut Healthy

State of Connecticut Department of Public Health

##### **Drinking Water Division**

410 Capitol Avenue – MS# 51WAT  
P.O. Box 340308 Hartford, CT 06134  
(860) 509-7333

**OVERVIEW** - The White's Bridge Lower Wellfield is located in an aquifer that is comprised largely of water-bearing sand and gravel deposits. The source water area is delineated by a preliminary Level B aquifer protection mapping area, which encompasses some 5808.6 acres of land in Bristol, Burlington, Farmington and Plainville. Vacant land and residential properties in the White's Bridge Lower Wellfield source water area presently account for approximately 91.5 percent of the land cover. Commercial development at 4.9 percent and agricultural land use at 3.5 percent, account for the remainder of the land coverage's in the source water area. Information about drinking water quality and treatment is available in the New Britain Water Department's annual Consumer Confidence Report.

**ASSESSMENT METHODS.**

The drinking water source assessment methods used by the Department of Public Health Drinking Water Division to evaluate the susceptibility of public drinking water sources to contamination are based on criteria individually tailored to surface water and groundwater sources. The criteria are keyed to sanitary conditions in the source water area, the presence of potential or historic sources of contamination, existing land use coverage's, and the need for additional source protection measures within the source water area. Source-specific data for community and non-community systems were used to determine whether a particular criterion should be rated as low, moderate or high, relative to the risk of potential contamination at the drinking water source. Further, a ranking system was used to compute an average rank for each community drinking water source based on its environmental sensitivity, potential risk of contamination and source protection needs.

Wellfields rated as having a low, moderate or high susceptibility to potential sources of contamination generally exhibit the characteristics summarized in Table 1.

**Table 1 – General Source Water Area Characteristics and Susceptibility Ratings**

<b>Susceptibility Rating</b>	<b>General Characteristics of the Source Water Area*</b>
Low	Low density of potential contaminant sources Lower intensity of land development
Moderate	Low to moderate density of potential contaminant sources Moderate intensity of land development
High	Moderate to high density of potential contaminant sources Higher intensity of land development No local aquifer protection regulations Detectable nitrates and/or volatile organic chemicals in the untreated source water during the past three years that are below the maximum contaminant levels allowed by state and federal drinking water regulations

*\* Note: Not all characteristics may be present for a given susceptibility rating*

*Readers of this assessment are encouraged to use the attached glossary to assist in the understanding of the terms and concepts used throughout this report.*

*Maps representing the location and features of the White's Bridge Lower Wellfield source water area have not been included with this assessment report because of homeland security concerns*

**WHITE'S BRIDGE LOWER WELLFIELD ASSESSMENT RESULTS.**

Based on a combination of current wellfield and source water area conditions, existing potential contaminant sources, and the level of source protection measures currently in place, the source water assessment for this wellfield indicates that it has an overall High risk of contamination from identified potential sources of contamination. It should be noted that this rating does not necessarily imply poor water quality or ongoing violations of the Connecticut Public Health Code. The assessment findings for the White's Bridge Lower Wellfield are summarized in Table 2, which lists current conditions in the wellfield source water area and recommendations or opportunities to enhance protection of this public drinking water source. A listing of potential contaminant source types in the area can be found in Table 3. A summary of source water area features is shown in Table 4.

The assessment of this and other comparable wellfields throughout Connecticut generally finds that adopting recommendations similar to those presented in Table 2 could reduce the susceptibility of most groundwater sources to potential sources of contamination.

Table 2

**Source Water Assessment Findings and Source Protection Opportunities  
White's Bridge Lower Wellfield**

Assessment Category	Conditions Through June 2002	Recommendations and Source Protection Opportunities
<p><b>Environmental Sensitivity Factors</b></p> <p><b>Contaminants Detected in Untreated Source Water</b></p>	<p>All wells in the White's Bridge Lower Wellfield are sited and constructed in accordance with DPH regulations and the most recent DPH sanitary survey of this wellfield indicates that it is free of deficiencies.</p> <p>None</p> <p>Except where noted above, any detected contaminants listed are below maximum contaminant levels (MCL) established by the federal government or guidance levels established by the Connecticut Department of Public Health. The presence of these contaminants, in general, indicates that this wellfield is sensitive to human activity.</p> <p><a href="#">Click here to review EPA's current drinking water standards</a>T</p>	<p>Maintain monitoring levels specified in the Connecticut Public Health Code Section 19-13-B102</p> <p>Encourage homeowners to adopt residential best management practices that minimize the use hazardous materials or generation of hazardous waste.</p>
<p><b>Potential Risk Factors</b></p>	<p>Potential contaminant sources in source water area</p>	<p>Periodically inspect SPCS sites and maintain a water quality monitoring program consistent with the level of potential risk</p> <p>Encourage residential property owners to conduct scheduled inspections and maintenance of underground fuel storage tanks and on-site septic systems.</p>
<p><b>Source Protection Needs Factors</b></p>	<p>Level B aquifer mapping completed</p> <p>Portions of the 200 foot sanitary radius around wellheads for this wellfield are not owned or controlled by the public water system.</p> <p>Less than 10% of this source water area is covered by local aquifer protection regulations</p> <p>Less than 10% of the land in the source water area exists as preserved open space</p>	<p>Complete Level A mapping</p> <p>Where feasible, increase ownership or control of 200 foot sanitary radius around all wellheads for this wellfield</p> <p>Expand coverage of local aquifer protection regulations throughout entire source water area</p> <p>Support and encourage the acquisition of open space land within the source water area</p> <p>Support environmental awareness and education within the community.</p>

Inventoried significant potential contaminant sources in the White's Bridge Lower Wellfield source water area are listed in Table 3. While these facilities have the potential to cause groundwater contamination, there is no indication that they are doing so at this time.

**Table 3 Summary of Significant Potential Contaminant Types in the White's Bridge Lower Wellfield Source Water Area**

Category	Subcategory	Number of SPCS Types
Waste Storage, Handling, Disposal	Hazardous Waste Facilities	13
	Solid Waste Facilities	0
	Miscellaneous	0
Bulk Chemical, Petroleum Storage	Underground Storage Tanks	41
	Tank Farms	2
	Warehouses	0
Industrial Manufacturing / Processing	Chemical & Allied Production	0
	Chemical Use Processing	14
	Miscellaneous	2
Commercial Trades and Services	Automotive and Related Services	42
	Chemical Use Services	7
	Miscellaneous	3
Agriculture and Related	Pesticide Storage, Handling or Application	0
Total Number of Contaminant Types		124

Prominent features of the White's Bridge Lower Wellfield source water area are summarized in Table 4.

**Table 4 Features of the White's Bridge Lower Wellfield Source Water Area**

Number and Type of Public Drinking Water Supply Wells	20 stratified drift wells
Source Water Area Delineation Method <sup>a</sup>	preliminary Level B
DEP Groundwater Classification	GAA - Groundwater used as a public drinking water supply, presumed to be drinkable without treatment
Size of Source Water Area	5808.6 acres
Location of Source Water Area	Bristol, Burlington, Farmington and Plainville
Predominant Land Use and Land Cover in Source Water Area <sup>b</sup>	
-Urban - Commercial or Industrial	4.9 %
-Urban - Residential	63.9 %
-Agricultural	3.5 %
-Undeveloped Land	27.6 %
Preserved Land In Source Water Area <sup>d</sup>	149.9 acres
Significant Potential Contamination Sources	
-Number of inventoried facilities in source water area	96
-Count of inventoried facilities per square mile	10.58 per sq mile
-Number of contaminant sources within inventoried facilities	124
Number of Contaminant Release Points Inventoried by CTDEP <sup>c</sup>	0

<sup>a</sup> Source water delineation method depends on data available for the wellfield

<sup>b</sup> Based on statewide data layer of land use and land cover developed by UCONN Dept of Natural Resource Management Engineering and Connecticut DEP satellite imagery.

<sup>c</sup> Sites or locations with documented accidental spills, leaks or discharges. While these sources, which are cataloged and tracked by the Connecticut DEP, may fall within a public drinking water supply source water area, they may or may not presently be discharging to the environment or causing contamination of a public drinking water source.

<sup>d</sup> Any combination of state forest and parklands and municipally or privately held land designated as open space.

# SOURCE WATER ASSESSMENT REPORT

## AN EVALUATION OF THE SUSCEPTIBILITY OF PUBLIC DRINKING WATER SOURCES TO POTENTIAL CONTAMINATION

CT0890011

### New Britain Water Department Shuttle Meadow Reservoir System

The State of Connecticut Department of Public Health (DPH) in cooperation with the Department of Environmental Protection (DEP) recently completed an initial assessment of the Shuttle Meadow Reservoir System, which is a source of public drinking water that is maintained and operated by the New Britain Water Department. This one-time assessment is part of a nationwide effort mandated by Congress under the Safe Drinking Water Act Amendments of 1996 to evaluate the susceptibility of all public drinking water sources in Connecticut to potential sources of contamination. DPH began working in partnership with the DEP in 1997 to develop Connecticut's Source Water Assessment Program, which was approved by the U.S. Environmental Protection Agency in 1999. Sources of potential contamination that are of concern to public drinking water supplies here in Connecticut are generally associated with historic waste disposal or commercial, industrial, agricultural and residential properties that store or use hazardous materials like petroleum products, solvents or agricultural chemicals.

The assessment is intended to provide New Britain Water Department consumers with information about where their public drinking water comes from, sources of potential contamination that could impact it, and what can be done to help protect it. This initial assessment complete will also assist the public water supply system, regional planners, local government, public health officials and state agencies in evaluating the degree to which the Shuttle Meadow Reservoir System may be at risk from potential sources of contamination. The assessment can be used to target and implement enhanced source water protection measures such as routine inspections, protective land use regulations, acquisition of critical land, proper septic system maintenance, and public education. General sources of contamination with the potential to impact the Shuttle Meadow Reservoir System include properties with underground fuel storage tanks, improperly maintained on-site septic systems, improper waste disposal, or commercial/industrial sites that store or use chemicals or generate hazardous wastes.

#### Shuttle Meadow Reservoir System Source Water Assessment Summary

##### STRENGTHS

**Point source pollution discharge points not present in this watershed area**

**20 to 30 percent of watershed area is owned by public water system**

**More than 30% of the land in the watershed area exists as preserved open space**

##### POTENTIAL RISK FACTORS

**Potential contaminant sources present in the watershed**

##### Susceptibility Rating

Rating	Environmental Sensitivity	Potential Risk Factors	Source Protection Needs
Low	X	X	X
Moderate			
High			

##### **Overall Susceptibility Rating: Low**

This rating indicates susceptibility to potential sources of contamination that may be in the source water area and does not necessarily imply poor water quality.

Detailed information about the specific factors and information used in establishing this rating can be found in Table 2. Information about opportunities to improve protection in the Shuttle Meadow Reservoir System is also presented in Table 2.



Keeping Connecticut Healthy

State of Connecticut Department of Public Health

##### Drinking Water Division

410 Capitol Avenue – MS# 51WAT  
P.O. Box 340308 Hartford, CT 06134  
(860) 509-7333

**OVERVIEW** - The Shuttle Meadow Reservoir System watershed encompasses some 14,459 acres of land in Berlin, Bristol, Burlington, New Britain, Plainville, Southington and Wolcott. Approximately 24.8% of this watershed is owned by the New Britain Water Department. Public drinking water sources in this system include North and South Hart Pond, Shuttle Meadow, Wasel, Whigville and Wolcott reservoirs and the White Bridge Brook Diversion. State-wide satellite imagery developed by the University of Connecticut indicates that undeveloped land and residential properties presently account for approximately 92.1% percent of the land cover in the Shuttle Meadow Reservoir System. Commercial development at 1.3% and agricultural land use at 6.6% account for the remainder of the land coverage in the source water area. Approximately 33.7% of the land in the watershed area is preserved including all watershed land owned by the New Britain Water Department, state forest and parklands, and municipally or privately held land designated as open space. Information about drinking water quality and treatment is available in the New Britain Water Department’s annual Consumer Confidence Report.

**ASSESSMENT METHODS.**

The drinking water source assessment methods used by the Department of Public Health Drinking Water Division to evaluate the susceptibility of public drinking water sources to contamination are based on criteria individually tailored to surface water and groundwater sources. The criteria are keyed to sanitary conditions in the source water area, the presence of potential or historic sources of contamination, existing land use coverage’s, and the need for additional source protection measures within the source water area. Source-specific data for community and non-community systems were used to determine whether a particular criterion should be rated as low, moderate or high, relative to the risk of potential contamination at the drinking water source. Further, a ranking system was used to compute an average rank for each community drinking water source based on its environmental sensitivity, potential risk of contamination and source protection needs. Watersheds and reservoirs rated as having a low, moderate or high susceptibility to potential sources of contamination generally exhibit the characteristics summarized in Table 1.

**Table 1 – General Watershed Area Characteristics and Susceptibility Ratings**

<b>Susceptibility Rating</b>	<b>General Characteristics of the Watershed Area*</b>
Low	Low density of potential contaminant sources Lower intensity of land development
Moderate	Low to moderate density of potential contaminant sources Moderate intensity of land development
High	Moderate to high density of potential contaminant sources Higher intensity of land development No local watershed protection regulations Detectable nitrates and/or volatile organic chemicals in the untreated source water during the past three years that are below the maximum contaminant levels allowed by state and federal drinking water regulations

*\* Note: Not all characteristics may be present for a given susceptibility rating*

*Readers of this assessment are encouraged to use the attached glossary to assist in the understanding of the terms and concepts used throughout this report.*

*Maps representing the location and features of the Shuttle Meadow Reservoir System source water area have not been included with this assessment report because of homeland security concerns.*

**SHUTTLE MEADOW RESERVOIR SYSTEM ASSESSMENT RESULTS.**

Based on a combination of current reservoir and watershed area conditions, existing potential contaminant sources, and the level of source protection measures currently in place, the source water assessment for this watershed system indicates that it has an overall Low risk of contamination from any identified potential sources of contamination. The assessment findings for the Shuttle Meadow Reservoir System are summarized in Table 2, which lists current conditions in the source water area and recommendations or opportunities to enhance protection of this public drinking water source. A listing of potential contaminant source types in the area, if present, can be found in Table 3. A summary of source water area features is shown in Table 4.

The assessment of this and other comparable watershed areas throughout Connecticut generally finds that adopting recommendations similar to those presented in Table 2 could reduce the susceptibility of most surface water sources to potential sources of contamination.

**Table 2 Source Water Assessment Findings and Source Protection Opportunities For the Shuttle Meadow Reservoir System**

Assessment Category	Conditions as of June 2002	Recommendations and Source Protection Opportunities
<b>Environmental Sensitivity Factors</b>  <b>Contaminants Detected in Untreated Source Water</b>	Predominant watershed topography characterized by moderate slopes Reservoirs have unknown capacity to support excessive growths of algae and plankton None <a href="#">Click here to review EPA's current drinking water standards</a>	Monitor runoff during heavy precipitation events Determine reservoir trophic status for source waters listed as unknown  Encourage homeowners to adopt residential best management practices that minimize the use of hazardous materials or generation of hazardous waste in the watershed.
<b>Potential Risk Factors</b>	Potential contaminant sources present in the watershed  More than 50% of land for this source water area is undeveloped, which could present a risk if developed inappropriately. Major state or interstate roadways present in the watershed  Known contaminant release points not present in the watershed	Periodically inspect these sites and maintain a water quality monitoring program consistent with the level of potential risk Proactively work with local officials and developers to insure that only low-risk development occurs within the watershed area Monitor road salt and herbicide usage along these roadways and address potential for hazardous material spills resulting from vehicular accidents  Encourage residential property owners to inspect and regularly cleanout onsite septic systems and replace underground fuel storage tanks with above ground tanks.
<b>Source Protection Needs Factors</b>	20 to 30 percent of watershed area is owned by public water system  Point source pollution discharge points not present in this watershed area	Support environmental awareness and education within the community.

Inventoried significant potential contaminant sources present in the Shuttle Meadow Reservoir System source water area are listed in Table 3. While these facilities, if present, have the potential to cause surface water contamination; there is no indication that they are doing so at this time.

**Table 3 – Summary of Significant Potential Contaminant Types in the Shuttle Meadow Reservoir System Source Water Area**

Category	Subcategory	Number of SPCS Types
Waste Storage, Handling, Disposal	Hazardous Waste Facilities	2
	Solid Waste Facilities	0
	Miscellaneous	0
Bulk Chemical, Petroleum Storage	Underground Storage Tanks	16
	Tank Farms	0
	Warehouses	0
Industrial Manufacturing / Processing	Chemical & Allied Production	0
	Chemical Use Processing	0
	Miscellaneous	0
Commercial Trades and Services	Automotive and Related Services	2
	Chemical Use Services	0
	Miscellaneous	0
Miscellaneous	No Identifiable SPCS Type	0
Agricultural Operations	Animal or Livestock Waste Handling	0
	Pesticide Storage or Application	1
Total Number of Contaminant Types		21

Prominent features of the Shuttle Meadow Reservoir System source water area are summarized in Table 4.

**Table 4 - Features of the Shuttle Meadow Reservoir System**

Location of Watershed Area	Berlin, Bristol, Burlington, New Britain, Plainville, Southington and Wolcott
Name of Reservoir(s) and Diversion(s)	North and South Hart Pond, Shuttle Meadow, Wasel, Whigville and Wolcott reservoirs and the White Bridge Brook Diversion
Number and Type of Public Drinking Water Reservoirs or Diversions in the Watershed	3 Distribution and Storage, 3 Storage, and 1 Transfer
Trophic Status of Reservoir(s)	7 Unknown
DEP Surface Water Classification	AA
Watershed Area (total acreage)	14,459 acres
Preserved Land in the Watershed <sup>a</sup>	4,873 acres
Predominant Watershed Topography	moderate slopes
General Land Use and Land Cover in the Watershed <sup>b</sup>	
-Urban - Commercial or Industrial	1.3%
-Urban - Residential	6.5%
-Agricultural	6.6%
-Undeveloped Land	85.6%
Significant Potential Contamination Sources	
-Number of inventoried facilities in source water area <sup>c</sup>	18
-Count of inventoried facilities per square mile	0.80 per sq mile
-Number of contaminant types within inventoried facilities	21
Number of Contaminant Release Points Inventoried by CTDEP <sup>d</sup>	0

<sup>a</sup> Preserved land includes any combination of land owned by the public water supply, state forest and parklands, and municipally or privately held land designated as open space.

<sup>b</sup> Based on statewide data layer of land use and land cover developed by UCONN Dept of Natural Resource Management Engineering and Connecticut DEP satellite imagery averaged across the entire watershed.

<sup>c</sup> Inventoried facilities reflect the actual number of SPCS sites present in the source water area, which may have more than 1 type of contaminant present at the facility.

<sup>d</sup>Sites or locations with documented accidental spills, leaks or discharges. While these sources, which are cataloged and tracked by the Connecticut DEP, may fall within a public drinking water supply source water area, they may or may not presently be discharging to the environment or causing contamination of a public drinking water source.